

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET CalAdvocates - SCE - 2021 WMP - 02

To: Cal Advocates
Prepared by: Cindy Jacobs
Job Title: Senior Manager
Received Date: 1/22/2021

Response Date: 2/12/2021

Question 001:

- a) How many SCE employees were qualified to perform climbing inspections of transmission towers as of January 1, 2021?
- b) How many SCE contractors were qualified to perform climbing inspections of transmission towers as of January 1, 2021?
- c) How frequently are SCE employee climbing inspectors of transmission towers requalified?
- d) How frequently are SCE contractor climbing inspectors of transmission towers requalified?
- e) Please respond to questions 1(a) and 1(b) with the appropriate numbers that correspond to January 1 of:
 - a. 2018.
 - b. 2019.
 - c. 2020.

Response to Question 001:

a) SCE’s inspection programs involve *ground-based* detailed and patrol inspections and *aerial* inspections. SCE does not have a climbing inspection program. Climbing of transmission towers may occur to perform maintenance or in response to an emergent condition.

b - e) See SCE’s response to part a above.