

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET CalAdvocates - SCE - 2021 WMP - 02

To: Cal Advocates
Prepared by: Raymond Fugere
Job Title: Principal Manager
Received Date: 1/22/2021

Response Date: 2/12/2021

Question 007:

- a) How many Level 1 corrective tags were issued as a result of transmission tower climbing inspections in 2020?
- b) How many Level 2 corrective tags were issued as a result of transmission tower climbing inspections in 2020?
- c) Please respond to questions 7(a) through 7(b) for:
 - i. 2018.
 - ii. 2019.

Response to Question 007:

- a) As noted in response to Question 1, SCE’s inspection programs involve ground-based detailed and patrol inspections and aerial inspections. SCE does not have a climbing inspection program.
- b) See response to part a.
- c) See response to part a