

*Southern California Edison*

*WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority*

**DATA REQUEST SET CalAdvocates - SCE - 2021 WMP - 09**

**To: Cal Advocates**  
**Prepared by: Kyle Ferree**  
**Job Title: Senior Advisor**  
**Received Date: 3/4/2021**

**Response Date: 3/9/2021**

---

**Question 010:**

The following questions relate to the use of live field observers (LFO) immediately prior to and during a PSPS event.

What information is gathered by the field observers beyond noting possible signs of failure or potential damages to SCE’s assets?

**Response to Question 010:**

SCE’s live field observers gather several key live weather data points. These include sustained and gust wind speeds, relative humidity and other conditions like the presence of lightning, precipitation and snow.

These observers also provide a valuable source of general situational awareness for any local conditions or considerations that should be relayed back to SCE’s Incident Management Team.