

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET CalAdvocates-SCE-2025WMP-09

To: Cal Advocates
Prepared by: Mike Freeman
Job Title: Sr. Advisor
Received Date: 4/23/2024

Response Date: 4/26/2024

Question 01:

In response to data request CalAdvocates-SCE-2025WMP-03, question 1, SCE provides the following table:

2023 WMP QC Inspections

2023 WMP QC Inspections		
Program	HFA Inspected	NC Structures
Overhead Detailed Inspections	3243	183
Transmission Inspections	529	3
Generation Inspections	156	5
Total	3928	191

- Define the term “HFA Inspected.”
- Provide the same table for 2020, 2021, and 2022.

Response to Question 01:

a) Define the term “HFA Inspected.”

HFA inspected refers to structures inspected in High Fire Areas that are designated as Tier 2 or Tier 3 in the High Fire Threat District (HFTD). HFA is synonymous with HFRA and HFTD in this context.

b) Provide the same table for 2020, 2021, and 2022.

Please see below.

2022 WMP QC Inspections		
Program	HFA Inspected	NC Structures
Overhead Detailed Inspections	4132	162
Transmission Inspections	532	11
Generation Inspections	150	7
Total	4814	180
2021 WMP QC Inspections		
Program	HFA Inspected	NC Structures
Overhead Detailed Inspections	4701	363
Transmission Inspections	742	12
Generation Inspections	120	8
Total	5563	383
2020 WMP QC Inspections		
Program	HFA Inspected	NC Structures
Overhead Detailed Inspections	17371	570
Transmission Inspections	380	2
Generation Inspections	38	3
Total	17789	575