

Southern California Edison
R.18-10-007 – SB 901

DATA REQUEST SET M G R A - S C E - 0 0 1

To: MGRA
Prepared by: Peter Lee
Job Title: Senior Business Analyst
Received Date: 3/3/2019

Response Date: 3/7/2019

Question 15: Are all trees of “at risk” or “reliability” species within the “strike zone” of utility equipment planned for trimming or removal? If arborist discretion is to be used, what factors will be used to determine which trees will be trimmed or removed, and what approximate fraction of “at risk” or “reliability” tree species will be trimmed or removed as enhanced vegetation management is implemented?

Response to Question 15:

All trees identified as “at risk” or “reliability” within the “strike zone” in 2019 will be planned for trimming and/or removal.

Factors and approximate fraction of “at risk” or “reliability” tree species are calculated through a risk matrix in a Tree Risk Assessment Tool, which takes into consideration:

- Overall Tree Condition
- Tree Defects
- Site Conditions
- Tree Lean
- Tree Height Factor
- Likelihood of Line Impact