

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET CalAdvocates - SCE - 2025 WMP - 12

To: Cal Advocates
Prepared by: Andrew Swisher
Job Title: Consulting Engineer
Received Date: 5/6/2024

Response Date: 5/9/2024

Question 01.a:

For the time period from January 1, 2019 to present, please state:

a) How many alarms SCE has had on fast-trip enabled protective devices

Response to Question 01.a:

a) How many alarms SCE has had on fast-trip enabled protective devices

SCE logged 1,908 fast curve alarms from recloser protective devices from Jan 2019 through May 6th, 2024. The fast curve alarm is disabled when fast curve tripping is enabled. The alarm was generally used during 2018, as part of the development of fast curve, to help understand the behavior of fast curve prior to enabling tripping later that year.