


Location Properties

| | | | |
|-----------------|------------|-----------------|------------|
| Technician: | [REDACTED] | Map Number: | [REDACTED] |
| Address: | [REDACTED] | Pole Tags: | [REDACTED] |
| City: | [REDACTED] | State: | [REDACTED] |
| County: | [REDACTED] | Zip Code: | [REDACTED] |
| Cross Street 1: | [REDACTED] | Cross Street 2: | [REDACTED] |
| Remedy: | [REDACTED] | Summary Notes: | [REDACTED] |
| Comments: | [REDACTED] | | |

Location Analysis Summary

| Layer | Pole Length/Class | Minimum Safety Factor | | | | | | Pole Strength Remaining | Loading Adjusted by Strength? | Clearance Violations Present? |
|-------------|-------------------|------------------------------|--------------|---------|-----------|-----------|----------------|-------------------------|-------------------------------|-------------------------------|
| | | Pole | Guy | Anchor | Cross Arm | Insulator | Sidewalk Brace | | | |
| As Designed | 45/2 | 3.31 from stress at 3' 3" | 3.96 (Guy#1) | No Data | No Data | No Data | No Data | 100% | Y | N |

Theoretical: As Designed



Analysis Results

Loading

| Component | In Service, 18 lb, Grade B (Governing Case) | | | In Service, Heavy, 6 lb, Grade B | | | Client File Maximum Rating |
|-----------|---|----------------------------|----------------|----------------------------------|----------------------------|----------------|----------------------------|
| | Safety Factor | Load (Applied / Allowable) | Wind Direction | Safety Factor | Load (Applied / Allowable) | Wind Direction | |
| Pole | 3.31 from stress at 3' 3" | 2293 / 600 lb/in | 260 ° | 11.9 from stress at 3' 3" | 638 / 600 lb/in | 260 ° | 600 lb/in |
| Guy#1 | 3.96 | 505 / 20000 lbf | 80 ° | 4 | 4256 / 20000 lbf | 80 ° | 20000 lbf |

Wire End Points and Wires

| WEP#1 | | | | | | | | | | | | | |
|-----------|----------------------|----------|-----------|---------------|-------------|------------------|--------------------|-----------------|----------------|----------------------------|-------|----------------------------------|--------|
| Type | Environment | Distance | Direction | GPS Point | Inclination | Measured Between | Measured to Ground | | | | | | |
| Next Pole | None | 234' | 355 ° | Undefined | 8 ° | N/A | N/A | | | | | | |
| ID | Size | Owner | Group | Tension Group | Height | Midspan | TAF | Initial Tension | Tension Method | In Service, 18 lb, Grade B | | In Service, Heavy, 6 lb, Grade B | |
| | | | | | | | | | | Tension | Sag | Tension | Sag |
| Wire#2 | 336.4 ACSR Tree Wire | SCE | Primary | Heavy Full | 37' 0" | 0' 0" | 1 | 892 lbf | Dynamic | 2482.73 lbf | 4' 5" | 3219.25 lbf | 3' 10" |
| Wire#3 | 336.4 ACSR Tree Wire | SCE | Primary | Heavy Full | 36' 9" | 0' 0" | 1 | 892 lbf | Dynamic | 2530.96 lbf | 4' 4" | 3238.44 lbf | 3' 10" |
| Wire#6 | 336.4 ACSR Tree Wire | SCE | Primary | Heavy Full | 36' 9" | 0' 0" | 1 | 892 lbf | Dynamic | 2434.88 lbf | 4' 6" | 3200.41 lbf | 3' 10" |

| WEP#2 | | | | | | | | | | | | | |
|---------------|-------------------|----------|-----------|---------------|-------------|------------------|--------------------|-----------------|----------------|----------------------------|---------|----------------------------------|--------|
| Type | Environment | Distance | Direction | GPS Point | Inclination | Measured Between | Measured to Ground | | | | | | |
| Previous Pole | None | 490' | 1 0 ° | Undefined | ° | N/A | N/A | | | | | | |
| ID | Size | Owner | Group | Tension Group | Height | Midspan | TAF | Initial Tension | Tension Method | In Service, 18 lb, Grade B | | In Service, Heavy, 6 lb, Grade B | |
| | | | | | | | | | | Tension | Sag | Tension | Sag |
| Wire#4 | 336.4 ACSR Oriole | SCE | Primary | Heavy Full | 37' 0" | 0' 0" | 1 | 1097 lbf | Dynamic | 2466.59 lbf | 14' 11" | 3217.09 lbf | 14' 6" |
| Wire#1 | 336.4 ACSR Oriole | SCE | Primary | Heavy Full | 36' 9" | 0' 0" | 1 | 1097 lbf | Dynamic | 2458.11 lbf | 14' 11" | 3214.53 lbf | 14' 6" |
| Wire#5 | 336.4 ACSR Oriole | SCE | Primary | Heavy Full | 36' 9" | 0' 0" | 1 | 1097 lbf | Dynamic | 2471.67 lbf | 14' 10" | 3219.58 lbf | 14' 6" |

| WEP#3 | | | | | | | |
|------------|-------------|----------|-----------|-----------|-------------|------------------|--------------------|
| Type | Environment | Distance | Direction | GPS Point | Inclination | Measured Between | Measured to Ground |
| Other Pole | None | 532' | 240 ° | Undefined | 12 ° | N/A | N/A |

Tension value used in an analysis may vary dependent on 'Average Length on Main Span' setting in the Load Case
 Tension value is inclusive of environmental and load factors associated with the Load Case
 Sag value is inclusive of environmental and load factors associated with the Load Case

Anchors

| Anchor#1 | | | | | | | | | | | | |
|--|-----------|--------|-----------|--------|------------|------------|--------------|-----------------|----------------------------|----------|----------------------------------|----------|
| Size | Owner | Lead | Direction | Height | Supporting | | | | | | | |
| 1 1/4" Triple Eye - Anchor Rod and Plate | SCE | 17' 0" | 263 ° | 0' 0" | Other | | | | | | | |
| ID | Size | Owner | Height | Angle | Brace ID | Brace Size | Brace Length | Brace Direction | In Service, 18 lb, Grade B | | In Service, Heavy, 6 lb, Grade B | |
| | | | | | | | | | Pretension | Tension | Pretension | Tension |
| Guy#1 | 7/16" EHS | SCE | 35' 0" | 26 ° | N/A | N/A | N/A | N/A | 584.41 lbf | 1.98 lbf | 584.41 lbf | 0.66 lbf |

Pretension values are calculated at 60°F (15.5°C) and without load factors
 Tension value is calculated without load factors or wind

| Cross Arms | | | | | | |
|------------|--------------------------|--------|-------------|-----------|--------|--|
| ID | Size | Height | Association | Direction | Offset | Insulators |
| CrossArm#1 | 12 Foot Double Cross Arm | 36' 6" | Other | 26 ° | 6' 0" | Insulator#1, Insulator#2, Insulator#3, Insulator#4 |

| Insulators | | | | | |
|-------------|---------------|-----------|--------|--------|--|
| ID | Size | Direction | Offset | Wires | |
| Insulator#1 | 16 kV Deadend | 355 ° | 0' 6" | Wire#3 | |
| Insulator#2 | 16 kV Deadend | 1 0 ° | 0' 6" | Wire#1 | |
| Insulator#3 | 16 kV Deadend | 355 ° | 11' 6" | Wire#6 | |
| Insulator#4 | 16 kV Deadend | 1 0 ° | 11' 6" | Wire#5 | |
| Insulator#5 | 16 kV Deadend | 355 ° | 3' 0" | Wire#2 | |
| Insulator#6 | 16 kV Deadend | 1 0 ° | 3' 0" | Wire#4 | |

Location 4757875E Location Forms

SAP

- Field Inspection Date: 11/18/2020
- High Fire: Extreme
- Special Project: No
- Associated Poles:
- Visible Damage: No
- Pole Type: ED
- District: 2 - Monrovia
- Region: ED SE METROEAS
- Above 3000 Ft Elevation: Yes
- As Designed Work Type: Existing
- Access Notes:

Pole Info Form

- Pole Equipment #: N/A
- Previous Inspection Date: N/A
- Year Installed:
- As Is POA Height:
- As Is POA Diameter:
- As Designed POA Height:
- As Designed POA Diameter:
- Thomas Guide/Quadrant: LA CO 46 6 D6
- Circuit : RED BOX 16KV
- Substation: RED BOX P T
- FIM: 9 84
- Location: SEC 22 T3N R11W 1215' W/O E/L 16 5' N/O S/L
- City: CLEAN
- Brand Height:
- Date Pole Load Performed:
- Comments:
- GPS Location: N/A

QC Comments

- QC Comments: