

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET CalAdvocates-SCE-2023WMP-18

To: Cal Advocates
Prepared by: Cindy Jacobs
Job Title: Senior Manager
Received Date: 7/11/2023

Response Date: 7/20/2023

Question 01:

This DR pertains to distribution outages only. The Quarterly Data Reports previously submitted did not include circuit names.

Please provide an Excel sheet listing each distribution outage that occurred from 2018 to 2022. The Excel sheet should list each outage in a row. Please provide the following information about each outage (as columns):

- a) Distribution Outage ID (unique code for each outage)
- b) CircuitID of the circuit affected (a number)
- c) Circuit Name
- d) Date that the outage started
- e) Time that the outage started (hh:mm:ss)
- f) Cause of outage
- g) For all equipment failure outages, please state the specific type of failure (i.e.: overhead transformer failure, overload, cross arms, underground transformer failure, cable failure, splice failure etc.)
- h) The outage duration in minutes
- i) The total number of customers impacted

Response to Question 01:

Please see the attached file titled, “CalAdvocates-SCE-2023WMP-18 Q1.xlsx”. The Outage Duration is the time elapsed from the beginning of the outage to the last restoration step of the outage. The outages are classified as either Momentary or Sustained. If any step in the outage is greater than 5 minutes, the outage is classified as Sustained. Otherwise, the outage is classified as Momentary.