

*Southern California Edison*  
*2025-WMPs – 2025-WMPs*

**DATA REQUEST SET CalAdvocates - SCE - 2025WMP - 03**

**To: Cal Advocates**  
**Prepared by: Arianne Luy**  
**Job Title: Engineering Manager**  
**Received Date: 3/22/2024**

**Response Date: 4/12/2024**

---

**Question 16:**

Please complete the table below to show how the Review & Revise process affects SCE's selection of system hardening initiatives (Wildfire Covered Conductor Program or Targeted Undergrounding):

- a) Circuit-miles of each system hardening initiative indicated before Review & Revise process
- b) Circuit-miles of each system hardening initiative indicated after Review & Revise process

**Response to Question 16:**

The table below shows approximate values of circuit miles forecasted for TUG and WCCP as of the beginning of 2024. Note that feasibility studies are still in progress and these miles may be subject to change based on results of the studies. Additionally, miles associated with existing TUG or WCCP projects were counted under their respective program. Also, these miles do not reflect potential additional miles added to scope due to operational considerations. The comparison before and after the Review and Revise process is based on the initial output of the WRRM 7.1 model which was implemented in August 2023.

Question 16 Table		
WMP Initiative	Before Review and Revise Process (Circuit) Miles	After Review and Revise Process (Circuit) Miles
Targeted Undergrounding	530	560
Wildfire Covered Conductor Program	2,120	2,130