

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET T U R N - S C E - 0 0 5

To: TURN

Prepared by: Raymond Fugere

Job Title: Principal Manager

Received Date: 3/10/2021

Response Date: 3/15/2021

Question 003:

Re. WMP, p. 215. SCE describes several programs (FRP, PLP, DPP) that replace wood poles. Please provide a spreadsheet that shows for 2019 and 2020 (in Excel) the number of poles replaced, and the total cost of replacement, for each of the main pole replacement programs.

Response to Question 003:

Please note the Fire-Resistant Pole program does not proactively replace poles, when a pole is being replaced in a High Fire Risk Area, such as for the Pole Loading Program, the pole is replaced with a fire-resistant pole. The table below contains the poles replaced under the Pole Loading Program and the Deteriorated Pole Program and the costs associated with those programs.

		2019 Recorded		2020 Recorded	
Program Type	Scope Type	\$(000s)	Qty	\$(000s)	Qty
Distribution	Det Pole	\$195,969	9,238	\$181,874	7,777
Distribution	PLP	\$157,859	7,192	\$96,960	3,310
Distribution		\$353,828	16,430	\$278,834	11,087
Transmission	Det Pole	\$85,368	3,156	\$92,810	3,027
Transmission	PLP	\$40,665	1,227	\$24,602	622
Transmission		\$126,033	4,383	\$117,413	3,649

Note 1: Includes total FERC and CPUC \$. Recorded \$s are expenditures recorded within that year.

Note 2: Distribution costs include under build expenditures.