

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET Cal Advocates - SCE - 2023 WMP - 08

To: Cal Advocates
Prepared by: Bryan Landry
Job Title: Senior Advisor – Strategic Planning
Received Date: 4/5/2023

Response Date: 4/7/2023

Question 05:

Referring to section 6.2.3 Key Assumptions and Limitations, Table 6-2, on p.148 of your WMP, SCE states that, "Additionally, SCE does not account for customer self-generation capabilities."

- a) Why doesn't SCE account for customer self-generation capabilities?
- b) Has SCE examined ways of accounting for customer self-generation capabilities?
- c) Will SCE make an effort to integrate customer self-generation capabilities into future strategies?

Response to Question 05:

- a.) Information regarding the self-generation capabilities for individual customers is incomplete and lacking sufficient quality for use in wildfire risk analysis.
- b.) SCE is working with Lawrence Berkeley National Labs to develop an update (ICE 2.0) to the Interruption Cost Estimate (ICE) Calculator. The ICE calculator is survey-based tool designed to inform decision making to improve grid design and customer resiliency. The results of this update, which will be available in late 2025, may provide additional insight into customer self-generation capabilities.
- c.) See response to part b.