

*Southern California Edison*  
*2022-WMPs – 2022 Wildfire Mitigation Plan Updates*

**DATA REQUEST SET CalAdvocates - SCE - 2022 WMP - 10**

**To: Cal Advocates**  
**Prepared by: Oscar Santos**  
**Job Title: Engr, Sr Mgr**  
**Received Date: 3/22/2022**

**Response Date: 3/25/2022**

---

**Question 05:**

How does SCE identify outdated or obsolete equipment (such as C-Hooks) in use as part of SCE's distribution or transmission systems?

**Response to Question 05:**

SCE objects to this data request on the grounds that it is overly broad and assumes facts not in evidence. Subject to these objections, SCE responds as follows: SCE performs routine and supplemental inspections of its distribution and transmission electric supply lines to identify facilities that require maintenance or replacement. The age of a facility does not automatically drive or determine necessary maintenance or replacement. When SCE moves forward with a new piece of equipment, we typically do not immediately replace all existing equipment. When the equipment needs to be replaced than we will replace it with the current standard equipment we are using. If it is determined that existing equipment should be replaced with the new piece of equipment than SCE would use our records, inspections, and field knowledge to inventory the equipment and replace them.