

Southern California Edison
2022-WMPs – 2022 Wildfire Mitigation Plan Updates

DATA REQUEST SET O E I S - S C E - 2 2 - 0 0 2

To: Energy Safety
Prepared by: Eric X Wang
Job Title: Sr. Manager
Received Date: 3/15/2022

Response Date: 3/18/2022

Question 10:

Consequence Modeling of Potential Incidents:

- a. In 2021, SCE post patrols found 46 incidents of wind-related damage on lines de-energized during PSPS events that could have potentially caused ignitions.
- i. Has SCE done any consequence modeling based on those damage points to better understand potential incidents that may have been prevented from the shut offs?

Response to Question 10:

SCE has not performed consequence modeling on those damage points using the actual weather conditions at the time of the events.