



NOTES:

1. PORTLAND CEMENT USED FOR GROUT SHALL BE TYPE II PORTLAND CEMENT CONFORMING TO ASTM C-150.
2. ALL ROCKS SHALL BE HARD, DURABLE, AND NOT DISINTEGRATE OR SOFTEN WHEN EXPOSED TO WATER OR WEATHERING. ROCK USED FOR WET CROSSING SHALL BE SMOOTH AND WITHOUT SHARP EDGES, AND SHALL HAVE A MINIMUM SPECIFIC GRAVITY OF 2.5

Southern California Edison (SCE) has no indication or reason to believe that there are any inaccuracies or omissions with information incorporated in this work and make no representation of any kind, including, but not limited to, the warranty of merchantability or fitness for a particular use, nor are any such warranties to be implied, with respect to the information or data furnished herein. No part of this map may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying and recording systems, except as expressly permitted in writing by SCE.

2007

**Tehachapi Renewable
Transmission Project PEA**

Figure 3.3-2. GROUTED ROCK WET CROSSING
TYPICAL INSTALLATION

