

Southern California Edison Company		
Monthly Peaks and Energy @ ISO (MWh)		
Month	Peak	Energy
Jan	11,495	6,868,163
Feb	11,520	6,471,603
Mar	10,908	6,542,648
Apr	12,921	6,262,058
May	13,649	6,877,281
Jun	16,474	7,612,515
Jul	18,280	8,991,631
Aug	19,434	9,334,681
Sep	20,758	8,423,291
Oct	15,582	7,366,315
Nov	11,800	6,517,496
Dec	12,092	6,868,929
Total	174,914	88,136,613

Southern California Edison Company	
2022 Monthly Eastwood Pump Amounts	
Month	Energy (MWh)
Jan	23
Sep	177
Total:	199

2020 True-Up Calculation		
2022 Forecast (MWh)	18,762	Reference: TO2022 Schedule 32, Line 2
True-Up Calculation (MWh)	(18,563)	= Total 2022 Actuals less 2022 Forecast

Note: 2022 was a dryer than normal water year and water levels in Shaver lake were below minimum levels in the first half of the year and therefore, pumping was not possible during that period

When conditions became suitable for pumping, Eastwood pump was then on outage during most of the second half of 2022 as a result of a circuit breaker failure.

Southern California Edison Company
2022 Daily Pump Load Amounts at Eastwood Pump

Year	MonthDay	HE	SC-EASTWOD-1
2022	01/03	13	22.63
2022	09/15	10	176.79
Total			199.42