

*Southern California Edison*

*WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority*

**DATA REQUEST SET T U R N - S C E - 0 0 5**

**To: TURN**

**Prepared by: Raymond Fugere**

**Job Title: Principal Manager**

**Received Date: 3/10/2021**

**Response Date: 3/15/2021**

---

**Question 002:**

Re. WMP, Initiative 7.3.4.9.1:

- a. Please identify in 2020 how many poles were i) repaired and ii) replaced as part of the remediation work.
- b. Please identify how much (capital and/or expense) was spent on pole remediations in 2020, disaggregated by repair and replacement if possible.

**Response to Question 002:**

- a) Per SCE’s system of record, SCE completed 3,543 pole replacements notifications and 11,065 repair notifications in 2020 in connection with inspections described in 7.3.4.9.1.
- b) SCE bundles repair work together, such as those from Inspection activities in 7.3.4.9.1 and other work to achieve operational efficiencies, and therefore cannot break out recorded costs without conducting a detailed study.