

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET CalAdvocates - SCE - 2025WMP - 09

To: Cal Advocates
Prepared by: Mike Freeman
Job Title: Senior Advisor
Received Date: 4/23/2024

Response Date: 4/26/2024

Question 05:

Provide the asset inspection QC data in the table below:

Response to Question 05:

Finding Categories	2020	2021	2022
High & moderate non-conformant structures			
Cotter pin not secured properly			
Secondary conductor damage			
Anchor damaged			
Service conductor damaged			
Pole Cavity			
Structure damaged			
Service conductor vegetation			
Primary insulator damaged			

See Table below:

Finding Categories	2020	2021	2022
High and moderate non-conformant structures	619	325	175
Cotter pin not properly secured	8	33	34
Secondary conductor damage	87	49	19
Anchor damage	3	1	15
Service conductor damaged	57	21	4
Pole cavity	2	0	0
Structure damaged	0	1	0
Service conductor vegetation	5	2	0
Primary insulator damaged	13	4	3