

Record ID	Actual Pole ID	IOU Provided Pole ID	Circuit ID	Latitude	Longitude	HFTD	Responsibility Area	Full Address	County	Zip Code	Wildfire Safety Concern Description	Risk Category	Utility Response re Planned Action to Resolve	If no planned action, provide rationale	Status of Corrective Action
SCE_CAC15_20231121_0856_2	6654T	6654T		36.05554	-118.9157397	Tier2	SRA	29141-30027 CA-190, Porterville, CA, 93257, USA	Tulare County	93257	_Dislodged avian mitigation cover found on ground. _Pole shows lean	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 01/06/2028
SCE_CAC15_20231121_0856_10	X16517E	X16517E		36.07511	-118.8802868	Tier2	SRA	30486-31498 Avenue 160, Porterville, CA, 93257, USA	Tulare County	93257	Pole lean approximately 9 degrees	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 9/01/2024
SCE_CAC15_20231128_0954_5	87855S	87855S		33.73831	-116.7213715	Tier3	SRA	Idyllwild School, 26700 CA-243, Idyllwild, CA, 92549, USA	Riverside County	92549	Dead and dying tree: pine with woodpecker holes throughout	Moderate	Planned 3/7/2024		Tree removed. Completed 04/04/2024
SCE_CAC15_20231128_0954_9	20220S	20220S		33.7389	-116.7188121	Tier3	SRA	54000-54056 Strawberry Valley Dr, Idyllwild, CA, 92549, USA	Riverside County	92549	Mid-span secondary triplex shows evidence of strain/delineation	Minor		Feedback from the SSP was as follows: No work required. Triplex is in contact with trees, but no stress, deflection or abrasion indicating a risk factor.	Vegetation Management Senior Specialist (SSP)confirmed Mitigated as of 3/1/24
SCE_CAC15_20231206_0801_1	1562615E	1562615E		34.36219	-119.3135917	Tier3	SRA	93001, Ventura, CA, USA	Ventura County	93001	Triplex secondary shows signs of strain	Minor		Feedback from the SSP indicated there was no signs of strain of abrasion. 2 Coastal Live Oaks were growing under the secondary triplex.	Vegetation Management Senior Specialist (SSP)confirmed Mitigated as of 2/29/24
SCE_CAC15_20231207_0821_1	48339397E	48339397E		34.39564	-119.2980284	Tier3	LRA	390 Old Grade Rd, Oak View, CA, 93022, USA	Ventura County	93022	Three splices on one phase	Minor	Correct pole ID is 4839397E	SCE District personnel field visited the location on 3/12/2024 and confirmed no action is required as the splices do not pose a safety concern or system reliability issue.	Feedback from the district was as follows: FS fielded this location and determined there is no system reliability concern here or safety issue involved
SCE_CAC12_20231115_0839_1	1319732E	1319732E		33.75314	-118.3091151	Tier2	LRA		Los Angeles County	90275	Dislodged avian mitigation cover	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 3/11/2025
SCE_CAC12_20231116_0819_4	1393409E	1393409E		33.7391	-118.3329857	Tier2	LRA				Dislodged avian mitigation cover	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 3/11/2025
SCE_CAC12_20231121_1214_7	473222E	473222E		36.12605	-118.8235102	Tier2	SRA	35182 Radeleff Ave, Springville, CA, 93265, USA	Tulare County	93265	Vegetation contacting guy wire above insulator	Minor	Notification was created for vegetation to be removed from down guy above the insulator.		Completed on 8/29/23
SCE_CAC12_20231205_0918_12	4659258E	4659258E		34.41924	-119.303187	Tier3	SRA	2430 Burnham Rd, Ojai, CA, 93023, USA	Ventura County	93023	Dislodged avian mitigation cover	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 09/11/2024
SCE_CAC12_20231207_0831_1	4881949E	4881949E		34.39572	-119.450798	Tier3	SRA	7200-7298 Casitas Pass Rd, Ventura, CA, 93001, USA	Ventura County	93001	Dislodged avian mitigation cover	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 09/11/2024
SCE_CAC12_20231207_0831_5	1562616E	1562616E		34.36217	-119.3133907	Tier3	SRA	93001, Ventura, CA, USA	Ventura County	93001	Down guy anchor soil not compacted	Minor	Integrated Inspection team confirmed Mitigated as of 3/11/24		Completed on 3/11/2024
SCE_CAC12_20231207_0831_6	692109H	692109H		34.40922	-119.3311051	Tier3	SRA	11071-11093 Santa Ana Rd, Ventura, CA, 93001, USA	Ventura County	93001	Dislodged avian mitigation cover	Minor	Notification has been created to remediate the concern.		Condition expected to be addressed by 09/11/2024
SCE_CAC14_20231213_0742_1	11764CWT	11764CWT		34.02275	-117.1520626	Tier2	LRA	1798 Canyon Rd, Redlands, CA, 92373, USA	San Bernardino County	92373	Tree limb hanging on tree	Severe	Confirmed, mitigated on 12/13/2023		Complete
SCE_CAC12_20231214_0854_2	1589195E	1589195E		33.99365	-117.1563702	Tier3	SRA	28944-29110 San Timoteo Canyon Rd, Redlands, CA, 92373, USA	Riverside County	92373	Communications cable loose and hanging at base of pole	Minor	Notification has been created to notify the communications service provider and remediate the concern.		Condition expected to be addressed by 09/09/2024