

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET CalAdvocates - SCE - 2020 WMP - 01

To: Cal Advocates
Prepared by: Raymond Fugere
Job Title: Manager
Received Date: 2/19/2020

Response Date: 2/24/2020

Question 002b:

Please clarify how SCE uses the term “near miss” in SCE’s 2020 Wildfire Mitigation Plan (and all associated data and metrics submitted to the Commission’s Wildfire Safety Division),

b) If the answer to question 2a is yes, please explain how SCE determines whether an event entails “significant probability of ignition.”

Response to Question 002b:

SCE interpreted “significant probability of ignition” as events that did not result in ignitions (faults and wire downs) where SCE determined that these types of events historically resulted in an ignition under certain circumstances, such as wire down, equipment failure, or contact from an object.