

Southern California Edison

WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3

DATA REQUEST SET Cal Advocates - SCE - 2020 WMP - 01

To: Cal Advocates
Prepared by: Raymond Fugere
Job Title: Manager
Received Date: 2/19/2020

Response Date: 2/24/2020

Question 002a:

Please clarify how SCE uses the term “near miss” in SCE’s 2020 Wildfire Mitigation Plan (and all associated data and metrics submitted to the Commission’s Wildfire Safety Division),

a) Does SCE use “near miss” as defined in the December 16, 2019 WMP Guidelines?²

(2. 2 Administrative Law Judge’s Ruling on Wildfire Mitigation Plan Templates and Related Material and Allowing Comment, R.18-10-007 December 16, 2019, Attachment 1, WMP Guidelines, (December 16, 2019 WMP Guidelines) p. 11.

“Near miss” means “An event with significant probability of ignition, including wires down, contacts with objects, line slap, events with evidence of significant heat generation, and other events that cause sparking or have the potential to cause ignition.”)

Response to Question 002a:

SCE used its interpretation of the WMP Guidelines’ definition of “near miss” for the types of events for which it has historical ignition data.