

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET C E J A - S C E - 0 0 1

To: CEJA
Prepared by: Brandon Sanders
Job Title: Sr. Project Manager
Received Date: 2/25/2020

Response Date: 2/27/2020

Question 010:

SCE describes plans for potential resiliency zones. WMP, p. 5-70. What type of technology would these resiliency zones employ? Would SCE consider vulnerabilities in population when determining the location for these zones?

Response to Question 010:

SCE is considering a variety of technologies for resiliency zones including renewable generation, storage, and traditional internal combustion generators both portable and semi-permanent. It is likely that a variety of technologies will be employed since each resiliency zone will have different customer, geographic, and technical requirements.

SCE will take population vulnerabilities into account when prioritizing communities for resiliency zones.