

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET M G R A - S C E - 0 0 4

To: 151
Prepared by: Andrew Swisher
Job Title: Consulting Engineer
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 010:

How many wireless fault indicators has SCE deployed as part of its Grid Modernization program?

Response to Question 010:

SCE deployment quantities for Remote Fault Indicators (RFIs) are not readily available specific to the Grid Modernization program. SCE can provide that 2,362 RFI installation locations are included in the 11,916 fault indicator installation locations identified in Table 15 of the 2020-2022 WMP.