

Southern California Edison

*WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3*

DATA REQUEST SET M G R A - S C E - 0 0 4

To: 151

Prepared by: Jose Ramon Goizueta

Job Title: Director Advanced Analytics

Received Date: 3/5/2020

Response Date: 3/10/2020

Question 002:

Does your utility use a wildfire risk ranking to prioritize circuits in the HFTD for remediation and improvements, and if so, which measures (hardening, enhanced vegetation management, etc.)?

Response to Question 002:

Yes, wildfire risk rankings are used for system hardening, overhead inspections, and vegetation management. These rankings for overhead inspections and vegetation management are for activities that extend beyond mandated compliance cycles/requirements.