

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET M G R A - S C E - 0 0 4

To: 151
Prepared by: Jose Ramon Goizueta
Job Title: Director Advanced Analytics
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 003:

Does your utility track multiple wildfire risk prioritizations per circuit, broken into individual risk, or calculate an aggregate risk score?

The following questions assume that a circuit risk ranking (or rankings) is in place. If your utility does not prioritize circuit remediation based on risk, no response is necessary and you can move to the next section.

Response to Question 003:

SCE calculates risk for individual assets (wire and components, switches, transformers, and capacitors). The individual risks calculated for these assets are equipment failure, and contacts from foreign objects including animal, balloon, vegetation, vehicles, and other. These individual risks can be aggregated or isolated to the specific location of the asset, the segment, or the circuit as needed.