

Southern California Edison
WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3

DATA REQUEST SET M G R A - S C E - 0 0 5

To: MGRA
Prepared by: Jose Ramon Goizueta
Job Title: Director Advanced Analytics
Received Date: 3/18/2020

Response Date: 3/20/2020

Question 003:

Does your utility track multiple wildfire risk prioritizations per circuit, broken into individual risk, or calculate an aggregate risk score?

Response to Question 003:

SCE calculates risk at the asset level for mitigation prioritization. Each asset risk is broken into risk of equipment fault, vegetation contact, balloon contact, vehicle contact, animal contact, and unknown/other; which represent the major drivers of the risk event.