

Southern California Edison
WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3

DATA REQUEST SET M G R A - S C E - 0 0 6

To: MGRA
Prepared by: Cindy Jacobs
Job Title: Senior Manager
Received Date: 3/26/2020

Response Date: 3/30/2020

Question 002:

What return interval is used to estimate maximum wind speed for wind loading purposes?

Response to Question 002:

A 30-year return interval was used.