

Southern California Edison
**WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3**

DATA REQUEST SET T U R N - S C E - 0 0 3

To: TURN
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/9/2020

Question 017:

Re. WMP Section 5.3.5.13. Please provide the results of the 2019 QC assessment of T lines and D lines. At a minimum, please provide data on the number and percentage of tree trims that met compliance and recommended clearance requirements.

Response to Question 017:

In 2019, between April 1 and December 31, QC inspection was performed on 88,843 trees in Distribution and 7,129 trees in Transmission. Results for trees that met the Regulation Clearance Distance (RCD) and recommended clearances (GRCD) are provided below:

Distribution	RCD	GRCD
	87,044 of 88,843 (97.98%)	52,008 of 88,843 (58.54%)

Transmission	RCD	GRCD
	7,124 of 7,129 (99.92%)	6,323 of 7,129 (88.69%)

Please note that trees identified as not meeting RCD were reworked by the trimming contractor(s).