

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET T U R N - S C E - 0 0 3

To: TURN
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/9/2020

Question 015:

Re. p. 5-96 re. “overhangs” – Please provide any additional information or quantification on how often it is “practical and achievable” for contractors doing routine VM to remove overhangs within HFRA.

Response to Question 015:

SCE’s work management system tracks removals and pruning, and one of the pruning prescriptions is “overhang.” Of SCE’s available data of completed work between June 1 and December 31, 2019, there were 427 completed overhang trims performed.