

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET T U R N - S C E - 0 0 3

To: TURN

Prepared by: Jose Ramon Goizueta

Job Title: Director Advanced Analytics

Received Date: 3/5/2020

Response Date: 3/9/2020

Question 008:

Was the SCE Wildfire Risk Model(WRM) used to develop SCE's 2020 WMP?

- a. If yes, explain how the WRM was used.
- b. If no, please explain why the WRM was not used.

Response to Question 008:

The WRM is used to prioritize mitigation activities by identifying the specific equipment with the highest risk within an asset class. The WRM is currently not capable of prioritizing across various mitigation programs so was not used to set program levels requested in the WMP. One exception to this was the WRM use in setting distribution inspection program levels per year in HFRA. This was possible because inspection programs use specialized resources that are not fungible with other programs.