

*Southern California Edison*  
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

**DATA REQUEST SET T U R N - S C E - 0 0 3**

**To: TURN**  
**Prepared by: BILL KOTTEAKOS**  
**Job Title: Senior Manager, Compliance**  
**Received Date: 3/5/2020**

**Response Date: 3/9/2020**

---

**Question 014:**

Please provide the average, minimum, maximum and 75% percentile of the time between tree inspections in 2017 and 2018.

**Response to Question 014:**

All trees in SCE's vegetation inventory are inspected annually during a predetermined inspection schedule. The exception to this scheduled process are some tree species that may not hold clearance during the annual inspection cycle. These trees are identified in our work management system as "cycle busters."