

*Southern California Edison*  
**WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3**

**DATA REQUEST SET W S D - S C E - 0 0 2**

**To: WSD**  
**Prepared by: BILL KOTTEAKOS**  
**Job Title: Senior Manager, Compliance**  
**Received Date: 3/5/2020**

**Response Date: 3/10/2020**

---

**Question 101 (SCE-43895-I-416):**

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-416

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Provide all procedures relating to substation vegetation management, as described in sections 5.3.5.17 and 5.3.5.18 on page 5-104.

**Response to Question 101 (SCE-43895-I-416):**

SCE does not have separate procedures for substation vegetation management at substations and uses the same procedures as the TVMP and DVMP, as applicable, for managing vegetation in and around substations. Inspections are conducted as indicated in Section 5.3.5.17 of our 2020-2022 WMP through normal inspection routines for GO 174 and any potential vegetation issues are flagged with notifications for follow up treatment as described in Section 5.3.5.18.