

*Southern California Edison*  
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

**DATA REQUEST SET W S D - S C E - 0 0 2**

**To: WSD**  
**Prepared by: BILL KOTTEAKOS**  
**Job Title: Senior Manager, Compliance**  
**Received Date: 3/5/2020**

**Response Date: 3/10/2020**

---

**Question 054 (SCE-43895-I-369):**

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-369

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

What criteria does SCE use to determine whether or not a tree is “adjacent to conductors,” as described in section 5.3.5 on page 5-95? Provide all supporting documents and procedures that outline this

**Response to Question 054 (SCE-43895-I-369):**

During the routine inspection process, SCE uses its clearance table guidelines to determine whether vegetation is “adjacent to conductors.” Therefore, any vegetation that falls within the clearance tables of the TVMP and/or DVMP is considered adjacent. Please reference SCE’s TVMP and DVMP, attached, as supporting documents (phone numbers of SCE employees redacted).