

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 056 (SCE-43895-I-371):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-371

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

In section 5.3.5 on page 5-95, SCE states that it “is still in the process of implementing this internal standard” when describing allowable vegetation within wire-zones in Tier 2 and Tier 3 HFRA. When does SCE anticipate such standard will be complete?

Response to Question 056 (SCE-43895-I-371):

Clearance of the referenced wire-zone is part of SCE’s expanded clearances on Transmission lines (30’ from point of maximum sag or sway). SCE anticipates this work will be completed in 2020 or 2021. It is further supported by SCE’s Integrated Vegetation Management (IVM) plan which is still in the early stages of development. SCE anticipates its IVM plan will be rolled out from 2021 to 2023.