

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 100 (SCE-43895-I-415):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-415

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Regarding section 5.3.5.16.2 on page 5-104:

a. What qualified a tree to be “active inventory”? Provide all relating procedures to identifying such trees.

b. What were SCE’s 2019 goals for DRI assessments and removals?

c. How many DRI assessments did SCE perform in 2019?

d. What are SCE’s 2020 goals for DRI assessments and removals?

Response to Question 100 (SCE-43895-I-415):

a. As stated in Section 5.3.5.16.2, “active inventory” is when SCE has both access and authorization to perform the removal.

b. SCE’s 2019 DRI goals were to: (1) Perform all quarterly DRI inspections, and (2) Remove identified dead, dying, or diseased trees in accordance with SCE’s vegetation management program.

c. SCE maintains a schedule of all required DRI planned inspections. However, due to the methodology used for DRI, SCE does not track individual tree assessments, but tracks trees identified for removal as part of the DRI assessment process. In 2019, 13,347 trees were removed (figure is being revised in Section 5.3.5.16.2 of SCE’s 2020-2022 WMP Revision 02 from what was originally reported, 13,627)

d. SCE’s 2020 DRI goal is to “Perform DRI annual inspection scope and complete prescribed

mitigations in accordance with DRI program guidelines.”