

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 080 (SCE-43895-I-395):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-395

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

When does SCE intend to complete its evaluation of already obtained LiDAR data?

Response to Question 080 (SCE-43895-I-395):

SCE has completed its evaluation of LiDAR data acquired in 2019 to determine when future flights will be needed. As a result, the required flight frequency for some circuits has been increased or decreased to reflect the vegetation conditions found. This evaluation was completed after the initial submission of SCE's 2020-2022 WMP and SCE will update its WMP accordingly. Additional evaluations will occur with each round of LiDAR results.