

*Southern California Edison*  
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

**DATA REQUEST SET W S D - S C E - 0 0 2**

**To: WSD**  
**Prepared by: BILL KOTTEAKOS**  
**Job Title: Senior Manager, Compliance**  
**Received Date: 3/5/2020**

**Response Date: 3/10/2020**

---

**Question 078 (SCE-43895-I-393):**

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-393

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Does SCE intend to perform LiDAR inspections around distribution facilities in the future?

**Response to Question 078 (SCE-43895-I-393):**

For the primary purposes of determining geospatial locations and long spans, SCE completed some LiDAR data capture around distribution facilities in 2019 and plans to capture LiDAR data from remaining distribution facilities in 2020. While SCE's vegetation management group would be alerted if a vegetation-related imminent threat was identified in a LiDAR scan, SCE is evaluating whether this data can be incorporated into its routine vegetation management inspection process. SCE's WMP will be updated for clarity on this point.