

*Southern California Edison*  
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

**DATA REQUEST SET W S D - S C E - 0 0 2**

**To: WSD**  
**Prepared by: Tom Rolinski**  
**Job Title: Fire Scientist**  
**Received Date: 3/5/2020**

**Response Date: 3/10/2020**

---

**Question 013 (SCE-43895-D-301):**

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-D-301

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.2 Situation Awareness and Forecasting

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

On page 5-54, SCE states that it aims to produce forecasts at higher resolutions (less than 2km). What is the current resolution of the forecasts generated by SCE?

**Response to Question 013 (SCE-43895-D-301):**

SCE currently generates through its vendor, Atmospheric Data Solutions, forecasts at a 2 km horizontal resolution.