

*Southern California Edison*  
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

**DATA REQUEST SET W S D - S C E - 0 0 2**

**To: WSD**  
**Prepared by: BILL KOTTEAKOS**  
**Job Title: Senior Manager, Compliance**  
**Received Date: 3/5/2020**

**Response Date: 3/10/2020**

---

**Question 069 (SCE-43895-I-384):**

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-384

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

What is the percentage of vegetation work that undergoes a quality assurance review and a quality control inspection, respectively?

**Response to Question 069 (SCE-43895-I-384):**

Quality Control (QC) is performed to verify field work (e.g., pre-inspection and pruning) meets applicable program standards. Quality Assurance (QA) is a process review and is not based on a percentage of vegetation work (please refer to UVM-07 for clarification).

SCE implemented its QC program on April 1, 2019. By year end 2019, SCE performed QC of line clearing on 3,025 HFRA and 1,681 Non-HFRA circuit miles. As a percentage, SCE targeted to QC inspect 20% of HFRA miles for T&D, 10% miles for T, and 5% miles for D. With the priority on implementing a QC program with a high sampling percentage in 2019, QA process reviews will be initiated in 2020.