

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 062 (SCE-43895-I-377):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-377

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

In section 5.3.5 on page 5-97, SCE states that its “trim distances are based on the CPUC’s recommended clearance distances.” Is this in reference to GO 95 Rule 35 Appendix E?

Response to Question 062 (SCE-43895-I-377):

Yes. SCE’s trim distances, when achievable, are based on GO 95 Rule 35 Appendix E.