

*Southern California Edison*  
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's  
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

**DATA REQUEST SET W S D - S C E - 0 0 2**

**To: WSD**  
**Prepared by: BILL KOTTEAKOS**  
**Job Title: Senior Manager, Compliance**  
**Received Date: 3/5/2020**

**Response Date: 3/10/2020**

---

**Question 091 (SCE-43895-I-406):**

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-406

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

What occurs when a tree remains a “subject tree” opposed to reclassification to a “hazard tree” or “reliability tree”, as discussed in section 5.3.5.16.1 on page 5-102.

**Response to Question 091 (SCE-43895-I-406):**

When a tree remains a subject tree, no further action is required other than adding the tree to the SCE HTMP inventory for awareness.