

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 102 (SCE-43895-I-417):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-417

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Provide in Excel format the number of ignitions, outages, near-misses, and incidents broken down by specific tree species from 2015 to 2019.

Response to Question 102 (SCE-43895-I-417):

SCE has provided a list of tree types from SCE's Tree Caused Circuit Interruption (TCCI) records. A TCCI record is created when SCE has had a circuit interruption due to vegetation. Our vegetation TCCI records do not document ignitions, outage durations, near-misses, and other incidents. TCCI records are intended to document the cause of the circuit interruption when it is vegetation related. Please see the attached Excel file "Interruptions_by_Tree_type.xlsx" which identifies the tree types which caused TCCIs between 2015 and 2019.