

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: Tom Rolinski
Job Title: Fire Scientist
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 006 (SCE-43895-D-294):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-D-294

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.2 Situation Awareness and Forecasting

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Which operational decisions use SCE's Fire Potential Index as an input?

Response to Question 006 (SCE-43895-D-294):

The Fire Potential Index (FPI) is one indicator used by SCE to determine which circuits are in scope for potential proactive de-energization during a Public Safety Power Shutoff (PSPS) activation/event.