

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 079 (SCE-43895-I-394):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-394

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Does SCE intend to perform any additional LiDAR inspections in 2020 for transmission facilities?

Response to Question 079 (SCE-43895-I-394):

Yes. SCE does intend to perform additional LiDAR in 2020 for Transmission facilities. SCE is currently in the process of completing its LiDAR data capture flight schedule for Transmission structures in 2020 in coordination with its risk-informed aerial inspection program.