

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/5/2020

Response Date: 3/10/2020

Question 059 (SCE-43895-I-374):

A. Item Index [For CPUC tracking purposes. Please reference this item index with the response provided.]

SCE-43895-I-374

B. Request Type

Request for additional specificity or clarification regarding information submitted in WMP or maturity survey

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

In section 5.3.5 on page 5-97, SCE states that “The HTMP assesses any tree in the HFRA utility strike zone (USZ) with the potential to strike the conductors should the tree or portion of the tree fail”.

a. To date, has SCE performed such assessment on all trees that qualify?

b. If so to above, how long did such assessment take to perform?

c. Does SCE intend to perform such assessment annually as part of the annual inspection?

Response to Question 059 (SCE-43895-I-374):

a. No, SCE commenced its HTMP in 2019 and performed 129,485 assessments as part of this program.

b. SCE anticipates performing HTMP assessments in its HFRA could take 5-8 years depending on identified tree inventory in the USZ.

c. HTMP assessments are independent of its compliance inspection program. The initial goal is to assess all trees with strike potential. SCE has not yet determined the frequency at which previously assessed subject trees will be revisited.