

Southern California Edison
**WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3**

DATA REQUEST SET W S D - S C E - 0 0 3

To: WSD
Prepared by: Raymond Fugere
Job Title: Principal Manager
Received Date: 3/13/2020

Response Date: 3/18/2020

Question 006- SCE-43900-Z -631:

A. Item Index

SCE-43900-Z -631

C. Relevant section of WMP (if applicable)

5.3.7.4

D. Relevant question in Maturity Survey (if applicable)

NA

E. Relevant meeting or call (if applicable)

NA

F. Specific Data request

Submit locations for near misses (areas where damage and/or faults nearly caused a fire).

G. Format in which the data is to be provided

GIS file

Response to Question 006- SCE-43900-Z -631:

SCE does not track the exact location where a fault occurred. SCE tracks the device that opened as a result of the fault. SCE downloaded the faults contained in its outage management system, and mapped those into the GIS file, titled *OutageData_Confidential*. Additionally, the excel file titled *faults.xlsx* contains all the faults, including those that could not be plotted. Please note SCE could not plot all the faults. SCE may not have been able to plot the faults due to the following:

- The asset was replaced, and the old asset number does not correspond to SCE's current mapping
- During the data collection of the outage, the location information did not match to an SCE structure