

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - 0 0 3

To: WSD
Prepared by: BILL KOTTEAKOS
Job Title: Senior Manager, Compliance
Received Date: 3/13/2020

Response Date: 3/18/2020

Question 012- SCE-43900-I-677:

A. Item Index

SCE-43900-I-677

C. Relevant section of WMP (if applicable)

5.3.5

D. Relevant question in Maturity Survey (if applicable)

E. Relevant meeting or call (if applicable)

F. Specific Data request

How does SCE prioritize vegetation management work (i.e. priority similar to Rule 18, risk ranking, etc.)?

G. Format in which the data is to be provided

Narrative

Response to Question 012- SCE-43900-I-677:

SCE's routine vegetation compliance program is managed on an annual schedule where all vegetation within SCE's service territory is inspected and pruning/trimming performed when required to achieve or maintain clearances. This schedule is predetermined using such factors as weather condition patterns and associated access requirements for inspection and trimming crews. Typically, routine compliance work is not prioritized based on risk unless short term tradeoffs are required, given the need to maintain clearance across the territory.

SCE's Hazard Tree Management Plan (HTMP) is prioritized using a risk-based scheduling process to promote efficient use of resources and to manage risk. Primarily, this involves considering risk consequence modeling performed by REAX Engineering when determining which specific areas or circuits are assessed first.