

Southern California Edison
***WSD-001 – Resolution WSD-001 to Establish Procedures for the Wildfire Safety Division's
Review of 2020 Wildfire Mitigation Plans Pursuant to PUC Sections 8386 and 8386.3***

DATA REQUEST SET W S D - S C E - V e r b a l - 0 0 1

To: WSD
Prepared by: Raymond Fugere
Job Title: Principal Manager
Received Date: 3/11/2020

Response Date: 3/16/2020

Question 002:

In Tables 11 a/b and 18 a/b, does SCE know the drivers in all the “Other” categories?. If not, why not as there are a large number of incidents in Tables 11 a/b with “Other?”

Response to Question 002:

SCE knows some of the “Other,” but it does not know them all. Some of the “Other” categories are listed as “Other - See Notes.” In order to determine the sub-drivers for these, this would be a manual process to get the details for these. Some of the sub-drivers of the “Other” categories are:

- Landslide/Mudslide
- Avoided Overload
- Lighting
- Lost Source
- Operations
- Ice/Snow

The large number of “Other” in 2019 is a result of when the data was pulled. Given that this data was pulled in early 2020, 2019 data had not been completely validated and the cause codes may have since shifted from “unknown” to the proper cause codes.