

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET CalAdvocates - SCE - 2021 WMP - 06

To: Cal Advocates

Prepared by: Christopher Tang

Job Title: Advisor

Received Date: 2/22/2021

Response Date: 2/25/2021

Question 009:

In what format(s) or database(s) has SCE tracked asset information for its Pole Loading Program between 2014 and 2020? (See WMP section 7.3.3.14)

Response to Question 009:

The Pole Loading Program (PLP) retains data used for safety factor calculations, including necessary asset data attributes in SPIDAcalc, SCE’s pole loading software. The PLP also collects certain pole asset information via a Hana database.