

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET G P I - S C E - 2 0 2 3 W M P - 0 2

To: GPI

Prepared by: Napa Tayavibul
Job Title: Senior Advisor, Compliance
Received Date: 5/11/2023

Response Date: 5/16/2023

Question 02:

Please provide the number of distribution line miles SCE will perform trimming on to achieve enhanced clearances (> 12').

Response to Question 02:

SCE has approximately 9,500 distribution circuit miles in its HFRA. We encourage our contractor crews to achieve expanded line clearing in HFRA to a distance of greater than 12 feet for distribution lines when possible. In 2022, SCE achieved an approximately 67% success rate in obtaining expanded line clearing across our entire network (which includes both HFRA and non-HFRA).