

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 4 - S C E - 0 2

To: Energy Safety
Prepared by: Jonathan Wuo
Job Title: Sr. Manager, Data Science
Received Date: 4/19/2024

Response Date: 4/24/2024

Question 02:

Regarding the changes in the circuit risk rankings due to risk model changes:

- a. Provide an Excel file of the 29 dropped circuits, the 29 new circuits, and the remaining 19 circuits in the top 5%² with the following:
 - i. Circuit name
 - ii. Risk score during the 2023-2025 WMP filing, broken out as follows:
 - (1) Overall utility risk score
 - (2) Ignition risk score
 - (3) Consequence risk score
 - (4) Top risk contributors
 - iii. Risk ranking during the 2023-2025 WMP filing
 - iv. Risk score during the 2025 WMP Update filing, broken out as follows:
 - (1) Overall utility risk score
 - (2) Ignition risk score
 - (3) Consequence risk score
 - (4) Top risk contributors
 - v. Risk ranking during the 2025 WMP Update filing

² SCE's 2025 WMP Update, page 16, Table SCE 1-01: Summary of Changes in Circuits due to POI and/or Consequence Risk Model Updates.

Response to Question 02:

Please refer to the attachment entitled "Q2 Response.xlsx". Please note that Overall utility risk score includes WF and PSPS risk score, while Ignition risk score only includes the WF risk score. Consequence risk score is the MARS consequence component of the WF risk score.